

# Emission Test Certificate

Tuesday, December 15, 2015

Supplier: Floating Floors Pty Ltd (14-16 Lakewood Boulevard, Braeside, VIC 3195)

Sample Description: Product No: 60126608 Batch No: 801378 - 12 mm thickness (floorboard)

Date Tested: September 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center"><b>Green Building Council of Australia</b>  <b>Green Star Office Design V3 IEQ -13</b></p>	<p align="center"><b>Product N<sup>o</sup>: 60126608</b> <b>Batch N<sup>o</sup>: 801378 -</b> <b>12 mm thickness</b> <b>(floorboard)</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.272 mg/m<sup>2</sup>/hr</p>
<p>4-phenylcyclohexene Emission Rate limit: &lt;0.05 mg/m<sup>2</sup>/hr</p>	<p>4-phenylcyclohexene Emission Rate: &lt;0.004 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
PhD, B.E. Chem.  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV150903a**